



GEO-CHEM LABORATORIES PVT.LTD.
Pragati, Adjacent to Crompton Greaves
Kanjur Marg (E), Mumbai 400042
Tel : +91 22 61915100 Fax : +91 22 61915101
Email : laboratory@geochem.net.in
CIN: U74220MH1964PTC013022

International
Independent Inspection
&
Testing Company

TEST CERTIFICATE

Analysis No. : MISC/14/06/003202

Date : 21/06/2014

Party's Name & Address : Watermaker (India) Pvt. Ltd.
Elphinstone Building, 1st Floor
10 Veer Nariman Road, Fort, Mumbai - 01.

Ref. No. and Date : Letter Dated 07/06/2014

Sample Received on : 09/06/2014

Date of Analysis : 09/06/2014 - 20/06/2014

Sample Described as : Water

Tested to Specification : IS-10500-2012 For Drinking Water

Stamped / Seal by : Sample drawn and sealed by Mr. Bhagyesh Sakpal of
Geo-Chem Laboratories Pvt. Ltd. on 07/06/2014
Seal No. : Geo-Chem 006896, 006897, 006898, 006899

ID Mark : Place and address of sampling : Samarth Aircon Pvt. Ltd.
Plot No. 2 & 3, Gut No. 302/2, 296/2
& 301, Village Kharivali, Taluka Wada,
Dist. Thane.

Place of sample drawn : Main gate passage area
Water Maker Machine

Source of water sample : Air Water

<u>Sr. No.</u>	<u>Parameters</u>	<u>Method</u>	<u>Requirements (Acceptable Limit)</u>	<u>Results</u>	<u>Detection Limit</u>	<u>Unit of Measure</u>
Table 1 Organoleptic and Physical Parameters						
1.	Colour (True Colour)	IS-3025-Part 4-1983	5 max.	N.D.	1.0	Hazen unit
2.	Odour	IS-3025-Part 5-1983	Agreeable	Agreeable	---	---
3.	pH value	IS-3025-Part 11-1983	6.5 to 8.5	6.52	1.0	---
4.	Taste	IS-3025-Part 8-1984	Agreeable	Agreeable	---	---
Rating scale 'b'						
5.	Turbidity	IS-3025-Part 10-1984	1.0 max.	N.D.	0.1	NTU
6.	Dissolved Solids	IS-3025-Part 16-1984	500 max.	33.0	1.0	mg/l

Continue on next page

Analysis No. MISC/14/06/003202, Dated 21/06/2014

Proforma No. GCLPL/QF/5.10/09

Issue No. 6

Page 1 of 4

Revision No. 0

1. Test Results related only to the sample (s) tested.

2. Test certificate in full or part shall not be reproduced unless written permission is obtained from M/s. Geo-Chem Laboratories (P) Ltd.

This inspection / testing has been performed to the best of our ability and our responsibility is limited to proven negligence. This certificate, which is issued on conditions stipulated overleaf, reflects our findings at the time and place of inspection / testing and does not relieve parties from their contractual obligations. Samples will be retained by us for a period of thirty days only, unless specific instructions to the contrary are received.





GEO-CHEM LABORATORIES PVT.LTD.
Pragati, Adjacent to Crompton Greaves
Kanjur Marg (E), Mumbai 400042
Tel : +91 22 61915100 Fax : +91 22 61915101
Email : laboratory@geochem.net.in
CIN: U74220MH1964PTC013022

International
Independent Inspection
&
Testing Company

<u>Sr. No.</u>	<u>Parameters</u>	<u>Method</u>	<u>Requirements (Acceptable Limit)</u>	<u>Results</u>	<u>Detection Limit</u>	<u>Unit of Measure</u>
Table 2 General parameters concerning substances Undesirable in Excessive Amounts						
7.	Aluminium (as Al)	IS-3025-Part 55-2003	0.03 max.	N.D.	0.010	mg/l
8.	Ammonium (total ammonia-N)	IS-3025-Part 34-1988	0.5 max.	N.D.	0.075	mg/l
9.	Anionic Detergent (as MBAS)	IS-13428-2005 (Annex-K)	0.2 max.	N.D.	0.1	mg/l
10.	Barium (as Ba)	Annex F of IS-13428	0.7 max.	N.D.	0.5	mg/l
11.	Boron (as B)	IS-3025-Part 2-2004	0.5 max.	0.025	0.010	mg/l
12.	Calcium (as Ca)	IS-3025-Part 40-1991	75 max.	3.54	1.0	mg/l
13.	Total Chloramines	IS-3025-Part 26-1986	4.0 max.	N.D.	1.0	mg/l
14.	Chloride (as Cl)	IS-3025-Part 32-1988	250 max.	0.96	0.1	mg/l
15.	Copper (as Cu)	IS-3025-Part 42-1992	0.05 max.	N.D.	0.010	mg/l
16.	Fluoride (as F)	IS-3025-Part 60-2008	1.0 max.	N.D.	0.1	mg/l
17.	Residual free Chlorine	IS-3025-Part 26-1986	* 0.2 min.	N.D.	0.1	mg/l
18.	Iron (as Fe)	IS-3025-Part 53-2003	0.3 max.	N.D.	0.010	mg/l
19.	Magnesium (as Mg)	IS-3025-Part 46-1994	30 max.	1.1	1.0	mg/l
20.	Manganese (as Mn)	IS-3025-Part 59-2006	0.1 max.	N.D.	0.050	mg/l
21.	Mineral Oil	IS-3025-Part 39-1991	0.5 max.	N.D.	0.5	mg/l
22.	Nitrate (as NO ₃)	IS-3025-Part 34-1988	45 max.	N.D.	1.0	mg/l
23.	Phenolic Compounds (as C ₆ H ₅ OH)	IS-3025-Part 43-1992	0.001 max.	N.D.	0.001	mg/l
24.	Selenium (as Se)	IS-3025-Part 56-2003	0.01 max.	N.D.	0.004	mg/l
25.	Silver (as Ag)	Annex J of IS-13428	0.1 max.	N.D.	0.005	mg/l
26.	Sulphate (as SO ₄)	IS-3025-Part 24-1986 (Gravimetric)	** 200 max.	N.D.	10.0	mg/l
27.	Sulphide (H ₂ S)	IS-3025-Part 29-1986	0.05 max.	N.D.	0.025	mg/l
28.	Total Alkalinity (as CaCO ₃)	IS-3025-Part 23-1986	200 max.	5.58	1.0	mg/l
29.	Total Hardness (as CaCO ₃)	IS-3025-Part 21-2009	200 max.	13.73	1.0	mg/l
30.	Zinc (as Zn)	IS-3025-Part 49-1994	5.0 max.	N.D.	1.0	mg/l
Table 3]: Parameters Concerning Toxic Substances :						
31.	Cadmium (as Cd)	IS-3025-Part 41-1992	0.003 max.	N.D.	0.001	mg/l
32.	Cyanide (as CN)	IS-3025-Part 27-1986	0.05 max.	N.D.	0.020	mg/l
33.	Lead (as Pb)	IS-3025-Part 47-1994	0.01 max.	N.D.	0.004	mg/l
34.	Mercury (as Hg)	IS-3025-Part 48-1994	0.001 max.	N.D.	0.0005	mg/l
35.	Molybdenum (as Mo)	IS-3025-Part 2-2004	0.07 max.	N.D.	0.010	mg/l
36.	Nickel (as Ni)	IS-3025-Part 54-2003	0.02 max.	N.D.	0.010	mg/l
37.	Total Arsenic (as As)	IS-3025-Part 37-1988	0.01 max.	N.D.	0.004	mg/l
38.	Chromium (as Cr+6)	IS-3025-Part 52-2003	0.05 max.	N.D.	0.010	mg/l
39.	Polychlorinated biphenyl (PCB)	GCLPL/QS/CRA/5.4/09 (GCMS)	0.0005	N.D.	0.0001	mg/l
40.	Polynuclear aromatic hydrocarbon (PAH)	GCLPL/QS/CRA/5.4/11 (GCMS)	0.0001	N.D.	0.0001	mg/l

Continue on next page

Analysis No. MISC/14/06/003202, Dated 21/06/2014

Proforma No. GCLPL/QF/5.10/09

Issue No. 6

Page 2 of 4

Revision No. 0

Sonawane

1. Test Results related only to the sample (s) tested.

2. Test certificate in full or part shall not be reproduced unless written permission is obtained from M/s. Geo-Chem Laboratories (P) Ltd.

This inspection / testing has been performed to the best of our ability and our responsibility is limited to proven negligence. This certificate, which is issued on conditions stipulated overleaf, reflects our findings at the time and place of inspection / testing and does not relieve parties from their contractual obligations. Samples will be retained by us for a period of thirty days only, unless specific instructions to the contrary are received.





International
Independent Inspection
&
Testing Company

GEO-CHEM LABORATORIES PVT.LTD.
Pragati, Adjacent to Crompton Greaves
Kanjur Marg (E), Mumbai 400042
Tel : +91 22 61915100 Fax : +91 22 61915101
Email : laboratory@geochem.net.in
CIN: U74220MH1964PTC013022

<u>Sr. Parameters No.</u>	<u>Method</u>	<u>Requirements (Acceptable Limit)</u>	<u>Results</u>	<u>Detection Limit</u>	<u>Unit of Measure</u>
41. <u>Individual Pesticides Residues</u>	GCLPL/QS/CRA/5.4/07, GCLPL/QS/CRA/5.4/08, (LCMSMS/GCMS/ GC ECD)				
Alachor		20	N.D.	0.015	µg/l
Atrazine		2	N.D.	0.015	µg/l
Aldrin and Dieldrin		0.03	N.D.	0.015	µg/l
Alpha - HCH		0.01	N.D.	0.0075	µg/l
Beta - HCH		0.04	N.D.	0.015	µg/l
Butachlor		125	N.D.	0.015	µg/l
Chlorpyrifos		30	N.D.	0.015	µg/l
Delta - HCH		0.04	N.D.	0.015	µg/l
2,4-D - dichlorophenoxyacetic Acid		30	N.D.	0.015	µg/l
DDT (o,p & p,p- isomers of DDT, DDE and DDD)		1	N.D.	0.015	µg/l
Endosulfan (α, β and Sulphate)		0.4	N.D.	0.015	µg/l
Ethion		3	N.D.	0.015	µg/l
Gamma HCH (Lindane)		2	N.D.	0.015	µg/l
Isoproturon		9	N.D.	0.015	µg/l
Malathion		190	N.D.	0.015	µg/l
Methyl Parathion		0.3	N.D.	0.015	µg/l
Monocrotophos		1	N.D.	0.015	µg/l
Phorate		2	N.D.	0.015	µg/l
42. <u>Trihalomethanes</u>	GCLPL/QS/CRA/5.4/19 (GCMS purge & trape)				
A) Bromoform		0.1	N.D.	0.001	mg/l
B) Dibromochloromethane		0.1	N.D.	0.001	mg/l
C) Bromodichloromethane		0.06	N.D.	0.001	mg/l
D) Chloroform		0.2	N.D.	0.001	mg/l

Continue on next page

Analysis No. MISC/14/06/003202, Dated 21/06/2014
Proforma No. GCLPL/QF/5.10/09

Issue No. 6

Page 3 of 4
Revision No. 0

1. Test Results related only to the sample (s) tested.

2. Test certificate in full or part shall not be reproduced unless written permission is obtained from M/s. Geo-Chem Laboratories (P) Ltd.

This inspection / testing has been performed to the best of our ability and our responsibility is limited to proven negligence. This certificate, which is issued on conditions stipulated overleaf, reflects our findings at the time and place of inspection / testing and does not relieve parties from their contractual obligations. Samples will be retained by us for a period of thirty days only, unless specific instructions to the contrary are received.





GEO-CHEM LABORATORIES PVT.LTD.
 Pragati, Adjacent to Crompton Greaves
 Kanjur Marg (E), Mumbai 400042
 Tel : +91 22 61915100 Fax : +91 22 61915101
 Email : laboratory@geochem.net.in
 CIN: U74220MH1964PTC013022

International
 Independent Inspection
 &
 Testing Company

Sr. No.	Parameters	Method	Requirements (Acceptable Limit)	Results	Detection Limit	Unit of Measure
Microbiological Parameters :						
43.	E. coli/MPN Index/100 ml	IS: 1622-1981	Absent	Absent [<2]	---	---
44.	Coliform bacteria/ MPN Index/100 ml	IS: 1622-1981	Absent	Absent [<2]	---	---
45.	Fecal coliform bacteria/ MPN Index/100 ml	IS: 1622-1981	Absent	Absent [<2]	---	---

Remarks : Sample conforms to IS-10500-2012 for Drinking Water Specification with respect to the tests carried out.

- Note :**
1. Our analytical findings reflect the quality of the sample at the time of testing. No responsibility can be accepted for the possible consequences of further development of micro-organisms which may depend upon storage, Handling and Weather conditions which may influence the results at a later date/time.
 2. N.D. : Not Detected.
 3. * To be applicable only when water is chlorinated. Tested at consumer end.
When protection against viral infection is required, it should be minimum 0.5 mg/l.
 4. ** May be extended to 400 mg/l provided that Magnesium does not exceed 30 mg/l.

For Geo-Chem Laboratories (P) Ltd.
 Authorised Signatory

(Signature)

Sharmila Sonawane
 Chemical Residual Analysis (Inorganic)

(Signature)

Bin Mohan
 Chemical Residual Analysis (Organic)

(Signature)

Kalpna Doke
 Biological Analysis



Analysis No. MISC/14/06/003202, Dated 21/06/2014
 Proforma No. GCLPL/QF/5.10/09
 SA/W

Issue No. 6

Page 4 of 4
 Revision No. 0

1. Test Results related only to the sample (s) tested.
 2. Test certificate in full or part shall not be reproduced unless written permission is obtained from M/s. Geo-Chem Laboratories (P) Ltd.
 This inspection / testing has been performed to the best of our ability and our responsibility is limited to proven negligence. This certificate, which is issued on conditions stipulated overleaf, reflects our findings at the time and place of inspection / testing and does not relieve parties from their contractual obligations. Samples will be retained by us for a period of thirty days only, unless specific instructions to the contrary are received.

