



International
Independent Inspection
&
Testing Company

GEO-CHEM LABORATORIES PVT.LTD.
Pragati, Adjacent to Crompton Greaves,
Kanjur Marg (E), Mumbai 400042.
Tel : +91 22 61915100 Fax : +91 22 61915101
Email : laboratory@geochem.net.in

TEST CERTIFICATE

Analysis No. : 1904K00793
Date : 10/04/2019

Party's Name & Address : Water Maker (India) Pvt. Ltd
Jeena Hpuse 170 Om Nagar Oft Marol
Pipe Line Road, Andheri (East), Mumbai - 400 099.

Ref. No. and Date : Letter Dated: 02/04/2019

Sample Received on : 04/04/2019

Date of Analysis : 05/04/2019 - 09/04/2019

Sample Described as : Water

Product Category : Water

Tested to Specification : IS-10500-2012 With Amendment No. 2 Sep 2018 For Drinking Water

Stamped / Seal by : Sample drawn and sealed by Mr. Popat Kekare of
Geo-Chem Laboratories Pvt. Ltd. on 04/04/2016
Seal No. : Geo-Chem 405426, 405428, 405429

ID Mark : Place and address of sampling : Water Marker (India) Pvt Ltd
Jeena Hpuse 170 Om Nagar Oft Marol
Pipe Line Road, Andheri (E)

Location of Sample drawn : Store Area
Source of Water Sample : Air Water

<u>Sr. Parameters No.</u>	<u>Method</u>	<u>Requirements (Acceptable Limit)</u>	<u>Results</u>	<u>Limit of Quantification</u>	<u>Unit of Measure</u>
Biological					
1	pH	IS-3025-Part 11-1983	6.5 to 8.5	7.38	--
2	Dissolved Solids	IS-3025-Part 16-1984	500 max.	54.0	mg/l
3	E. coli/MPN Index/100 ml	IS: 15185 - 2016	Absent	Absent	--
4	Coliform bacteria/MPN Index/100 ml	IS: 15185 - 2016	Absent	Absent	--
5	*Fecal coliform bacteria/MPN Index/100 ml	IS: 1622-1981	--	<2	--

Remarks : Sample conforms to IS-10500-2012 With Amendment No. 2 Sep 2018 for Drinking Water Specification with respect to the tests carried out.

- Note :**
- 1 Our analytical findings reflect the quality of the sample at the time of testing. No responsibility can be accepted for the possible consequences of further development of micro-organisms which may depend upon storage, Handling and Weather conditions which may influence the results at a later date/time.
 - 2 *Parameter not in 10500:2012

For Geo-Chem Laboratories (P) Ltd.
Authorised Signatory

Sharmila Senawang
Sharmila Senawang
Chemical Residual Analysis (Inorganic)

Priyanka Shinde
Priyanka Shinde
Biological Analysis

Revision No. 0 Page 1 of 1

UJ

Proforma No. GCKJM/QF/5.10/01

Issue No. 7

~ This is not included in our scope of accreditation.

ULR No.: TC7284190K00374M0F

1. Test Results related only to the sample (s) tested.
 2. Test certificate in full or part shall not be reproduced unless written permission is obtained from M/s. Geo-Chem Laboratories Pvt. Ltd.
 3. Geo-Chem Laboratories Pvt. Ltd. is not responsible for the authenticity of photocopied or computer scanned reports / certificates.
- This inspection / testing has been performed to the best of our ability and our responsibility is limited to proven negligence. This certificate, which is issued on conditions stipulated overleaf, reflects our findings at the time and place of inspection / testing and does not relieve parties from their contractual obligations. Samples will be retained by us for a period of thirty days only, unless specific instructions to the contrary are received.

